

**Malaviya National Institute of Technology Jaipur – 302017**  
**Department of Electronics & Communication Engineering**

---

**CORRIGENDUM**

**Tender Notice No. F5(1370)ST/MNIT/ECE/2019**

The following amendments are hereby amendments of above mentioned item.

**Amendments in Technical Specifications**

<b>Sr. No.</b>	<b>Item / Particular</b>	<b>Specification in original Tender</b>	<b>Amendments in Specification</b>
1	UPS	Make : APC/Consul/Emerson UPS Rating 10 KVA (9 KW) With 1Hrs. Backup Time 32 BIT, DSP Controlled UPS With Input Galvanic Isolation Transformer Input Power Factor : 0.99 (100% Load) Output Power Factor : 0.9 (100% Load) IGBT Rectifier and Inverter 3/1 Phase Input 1 Phase Output Efficiency Ac Mode : Above 91% Efficiency ECO Mode : Above 98% DC Volt : 192 to 240 VDC Hot Standby/Parallel Configuration AutoStatic Bypass and Manual Bypass Minimum 1 Hrs. Backup Time(12480 VAH)	UPS Rating 10 KVA (9 KW) With 1Hrs. Backup Time 32 BIT, DSP Controlled UPS With Input Galvanic Isolation Transformer Input Power Factor : 0.99 (100% Load) Output Power Factor : 0.9 (100% Load) IGBT Rectifier and Inverter 3 Phase Input 1 Phase Output Efficiency Ac Mode : Above 91% Efficiency ECO Mode : Above 98% DC Volt : 192 to 240 VDC Hot Standby/Parallel Configuration AutoStatic Bypass and Manual Bypass Minimum 1 Hrs. Backup Time(12480 VAH)

The date of submission and opening of tender is also hereby extended up to 22.10.2019 in place of earlier date of 14.10.2019. However the time thereof and other terms conditions of our earlier E-NIT will remain unchanged.

Deputy Registrar  
(Store & Purchase)