

Malaviya National Institute of Technology Jaipur
Jawahar Lal Nehru Marg, JAIPUR-302017 (Rajasthan)
Ministry of Education
(Government of India)



Page 1 of 9

**Open Tender Enquiry
For**

**Procurement of Lighting work of table tennis and basket
ball courts near Arobindo hostel**

MALAVIYA NATIONAL INSTITUTE OF TECHNOLOGY JAIPUR

No. F8(67)MNIT/Estate/2021-22

Phone : 0141-2713312,2713352

NOTICE INVITING QUOTATIONS

Registrar MNIT, JLN Marg, Jaipur invites sealed tenders for the supply of “**Lighting work of table tennis and basket ball courts near Aurobindo Hostel**” of this Institute in **Single Bid System** as per schedule given below:

| Schedule | |
|--|--|
| Event | Date & Time |
| Download of Tender | 11.07.2022 |
| Bid Submission Last Date & Time | 03.08.2022 by 2.00 PM |
| Bid Opening Date & Time | 03.08.2022 at 3.00 PM |
| Earnest Money | (Rs. 65,0000.00) EMD in the form of Demand Draft in the name of The Registrar, MNIT payable at Jaipur or NEFT/RTGS in the bank account details as under:- Bank Name: ICICI Bank Ltd., Bank Branch: MNIT Jaipur Account Holder: Registrar MNIT Jaipur, J.L.N. Marg, Jaipur Bank Account No: 676805000011 Bank IFSC Code: ICICI0006768 |
| Performance Bank Guarantee | 3% of the contract value valid till warranty period plus 60 days. |
| Warranty | Standard OEM warranty not less than 1 year |
| Delivery | 60 Days |
| Bid Validity days | 90 days |
| Email Address (for Technical Clarifications) | storepurchase@mnit.ac.in |

Quotation must be enclosed in a properly sealed envelope addressed to **Deputy Registrar (S&P), Malaviya National Institute of Technology, Jawahar Lal Nehru Marg, Jaipur -302017** (E-mail address storepurchase@mnit.ac.in) by designation and not by name. The quotations must be super scribed “Quotations for the supply of “**Lighting work of table tennis and basket ball courts near Aurobindo Hostel**”” as called for in Tender Notice No. ----- dated _____ due on----- at ----- AM/PM. The Quotation must reach on or before the due date and time mentioned in the ‘**Schedule**’. The documents must be dropped in the tender box available in Central Store during office hours (9.30am to 6.00pm) on all working days. Bids delivered to any other place or any individual shall not be considered as valid document. Quotations sent by e-mail will also not be considered valid. The complete Tender document can be viewed and downloaded only from the website (www.mnit.ac.in) and CPPP site <https://eprocure.gov.in/epublish/app> during the tender period.

2. INVITATION FOR TENDER OFFER FOR PROCUREMENT OF “LIGHTING WORK OF TABLE TENNIS AND BASKET BALL COURTS NEAR AUROBINDO HOSTEL”

Malaviya National Institute of Technology, Jaipur (MNIT) invites bids from eligible and experienced OEM (Original Equipment Manufacturer) or OEM Authorized Dealer for procurement of ‘**Lighting work of table tennis and basket ball courts near Aurobindo Hostel**’ (warranty period as stated at “Schedule”) on site comprehensive warranty from the date of receipt of the material as per terms & conditions specified in the tender document.

TECHNICAL SPECIFICATION:

| S.No. | Description of items | Unit | Qty |
|------------------------------|---|------|-----|
| A. Basket ball courts | | | |
| 1 | Supply of MS swaged tubular pole conforming to IS:2713-1980 (part I to II) with galvanised base plate, cable entry, GI cable sleeve complete as required. painted with two coat of redoxide primer and two quote of enamel paint of silver colour as per the direction of Engineer in charge. The pole shall be fabricated by using ISI mark tube for structural purpose of following height & designation. (See Table P-02 for specs.) complete in all respect. All as per pre approved by Engineer in charge. For additional technical parameters of products / work, refer Annexure "A" attached with this BSR . (410 SP - 60) Overall Height - 12 Mtr. Base Plate Size - 400 x 400 x 7 mm Length of sections - Bottom - 5.8 mtrs, Middle- 3.1 mtrs, Top - 3.1 mtrs. Outside dia. & thickness of sections - Bottom - 165.1 mm x 5.4 mm, Middle- 139.7mm x 4.5mm, Top - 114.3mm x 3.65mm. | Each | 9 |
| 2 | M.S. Sections- 40mm x 40mm X 2.6 mm (thikness)(Make : APOLLO, KALINGA, SWASTIK) | Mtrs | 60 |
| 3 | Providing of thermoplastic Polycarbonate cable junction boxes with IP66 rating of protection & knock out for cable entry/out of following sizes including clamps for holding the box, including cost of DIN rail for MCB mounting, 10 Sqmm 4 pole connectors for cables terminals, threaded cable glands made of polyamide material etc. complete in all respect. For additional technical parameters of products/ work , refer Annexure "A" attached with this BSR . 175mm X 150mm X100mm (Make : HPL, Sintex, United) | Nos. | 12 |
| 4 | Supply of 240/415V AC MCB with positive isolation of breaking capacity not less than 10KA (C tripping characteristic as per type of load and site requirement) 4KV impulse with stand voltage, as per PWD specification for electrical Works with ISI marked IS8828(1996)/conforming to IEC60898-12002, IEC60947-2. Single pole MCB - 10 A rating (Make: Schneider (neo break), Siemens, HPL, GE , Standard, Indoasian(gold), Havell's, C & S, ABB (S270), L&T, Legrand (Ekinoxe / Lexic)) | Each | 28 |
| 5 | Supply of P.V.C. / XLPE insulated & P.V.C. sheathed Armoured aluminium cable of 1.1 KV grade as per PWD specification for electrical Works. - 6.0 Sq. mm, 4 core (Make : Gloster ,CCI, Finolex, Rallison, Ekta, Delton, Havell's, KEI, Paramount, Worldcab, Diatron, Unicab, Unistar, Orient cab, Empire, Orbit, Polycab, National) | Mtrs | 300 |

| | | | |
|----|--|-------|-----|
| 6 | Supply of P.V.C. / XLPE insulated & P.V.C. sheathed Armoured aluminium cable of 1.1 KV grade as per PWD specification for electrical Works. - 70.0 Sq. mm, 3.5 core (Make : Gloster ,CCI, Finolex, Rallison, Ekta, Delton, Havell's, KEI, Paramount, Worldcab, Diatron, Unicab,Unistar, Orient cab, Empire, Orbit, Polycab, National) | Mtrs | 50 |
| 7 | Supply of P.V.C. / XLPE insulated & P.V.C. sheathed Armoured aluminium cable of 1.1 KV grade as per PWD specification for electrical Works. - 120.0 Sq. mm, 3.5 core (Make : Gloster ,CCI, Finolex, Rallison, Ekta, Delton, Havell's, KEI, Paramount, Worldcab, Diatron, Unicab,Unistar, Orient cab, Empire, Orbit, Polycab, National) | Mtrs | 120 |
| 8 | Supplying ISI marked P.V.C. insulated submersible cable copper wire as per PWD specification for electrical Works confirming to IS:694 and as per IS 8130 : 2013 of 1.1 kV grade. Insulation PVC type A, flame retardant as per IS 10810-53. - 1.5 Sq.mm 3 core Round copper cable (Make RR Kabel , National, Finolex, Rallison, Delton, Eon (Indoasian), KEI, Terexal, Plaza, Anchor, L & T, Standard, Paramount, Empire, Orient Cab, Orbit, HPL, Unicab, Polycab, Havell's, Diatron) | Mtrs. | 400 |
| 9 | Supply of IK07IP-66 protected high power LED flood light system with Pressure diecast aluminium housing LM6/ADC12 material, toughened glass diffuser with suitable lenses on LED to achieve various beam angles, 240 volt, 50Hz, of high power LED lamps. Integrated driver must be potted & has a unique BISR number shall be high efficiency having efficiency more than 85% and in compliance to BIS certified and T.C. certificate. The System level Luminaire efficacy ≥ 120 lm/wt with High Power LEDs is to be used. LED driver Input Voltage AC120 to 270VAC with High voltage Cut off ≥ 300 VAC and Auto resetting Safety. Input Frequency 50Hz $\pm 3\%$, Power Factor > 0.95 , driver Efficiency $> 85\%$, THD(I) $< 10\%$, driver current < 1000 mA shown in LM79 report. driver should be Phase to phase protection of 440V for 4Hrs. Electrical Connector Must be provided, Surge Protection Min ≥ 4 KV internal and 10KV external, System life of 30000 Burning hours with 70% of Initial Lumens maintained, color Rendering Index > 70 and CCT 5700K ± 355 K. Manufactures Word Mark/Name Engraved /Embossing/ Screen printing on die cast housing to allow trace ability/authenticity. Fixture shall be IS 10322 Complianted. High Power with stand LED Flood Light 400W (Make : CG, Bajaj, Wipro, Surya, Havell's, HPL, GE, Pierlite, Halonix Philips, CG, Bajaj, Wipro, Surya, Havell's) | Each | 28 |
| 10 | Supply of material for Plate Earthing as per PWD specification for electrical Works as per IS:3043 with copper Earth plate of size 600mm x 600mm x 3.0mm. 20 mm dia. G.I. 'B' class watering Pipe (3m), including all accessories like nut, bolts, reducer, nipple, wire meshed funnel, and Heavy duty weather proof polypropylene earth pit chamber with lockable Jam free lid suitable for safe working load 5000 Kg or more of size Top Dia. 225 to 260 mm, Bottom Dia 300 to 350 mm. and Height 250 to 300 mm. salt and coke/ charcoal as per norms. | Set | 1 |

| | | | |
|----|---|-----|---|
| 11 | <p>Fabrication, Supply of outdoor type cubical type LT panel suitable for 415 V, 3 Phase, 4 Wire 50 Hz AC supply system having front surface area as per approved design. The panel should be fabricated in compartmentalized (preferably) design from CRCA sheet steel of 2.0 mm thick for frame work & covers (panel Structure), 1.6 mm thick for door, 3 mm thick for gland plates. Nine tank cleaning process from chemical treatment of the sheet for best finish & quality coating. Powder coating complete with 7 tank process for powder coating in approved shade. The panel having 1000 Amp capacity extensible type TPN aluminium alloy bus bars of high conductivity, DMC/ SMC bus bar supports. Bottom base channel of MS section not less than 100 mm x 50 mm x 5 mm thick ((Hight 900 mm), fabrication shall be done in transportable sections, entire panel shall have a common GI earth bar of size 50 mm x 6 mm at the rear with 2 Nos. earth stud, solid connections from main bus bar to switch gears with required size of Al. bus bars and control wiring (with PVC insulated FRLS copper wire of required size, terminal, lugs, Tape, hardware & accessories), cable alleys, cable gland plates in two half, panel tested up to 6300A at 80 KA @690V, including providing following switch gears:-</p> <p>Incoming</p> <p>01 No. 200 Amps, 36KA 4 Pole Microprocessor type MCCB with Ics=100%Icu with O/L, S/C & E/F protection complete, having on & off trip indication lamp and Spreader Link.</p> <p>LED Multifunction Meter having V, A, F, PF, kW, kVA, kVAR, kWh, kVAh, kVARh, Runhours, On hours, Interrupts, RPM*, % Unbalance (V, A), Phase angle, THD, Neutral current, % Load, Maximum Demand (kW & kVA), MD reset with suitable Accessories- 1 Set with suitable CT's (10VA, 200/5A) and back up MCBs.</p> <p>3 Nos. Phase indicating LED lamps with backup MCBs, breaker ON/OFF/Trip indication light, test terminal block set, MCB , circuits as per standard practice , auxiliary contact for positive interlocking of the breakers, Shunt Trip Coil 220 V AC as required .</p> <p>Bus Bars - TPN aluminium bus bars of minimum 1000 Amp capacity with heat shrinkable coloured sleeves and including DMC/SMC bus bar Cross Section side supports and their spacing etc, for withstanding fault as per CPRI complete with wiring, terminals, lugs, PVC channel with accessories, GI Earth Bus (25x6MM).</p> <p>Outgoing</p> <p>3 Nos. 100 Amps, 18KA 4 Pole Thermal Magnetic Release type MCCB with Ics=100%Icu with O/L, S/C protection complete with spreader link.</p> <p>3 Nos. 63 Amps, 18KA 4 Pole Thermal Magnetic Release type MCCB with Ics=100%Icu with O/L, S/C protection complete with spreader link.</p> <p>NOTE:- 1) MCCB's wherever specified shall have extendable rotary handle. 2) All MCCB's shall be provided with phase barriers, phase spreaders link complete as required. Page 5 of 9 3) The drawing of L.T. Panel to be got approved from Department before fabrication. The panel may be tested in front of representative of the Institute before dispech. The commissioning may be done by the manufacturer after installation. 4) Manufactured by : Seimens, Mile stone, coremetal craft Ltd., AdLac, Advance, Johns Electric, Neptune. Make of the Swithgears : ABB, Legrand, Schneider, Seimens, L&T</p> | Set | 1 |
|----|---|-----|---|

| | | | |
|----|---|-----|---|
| 12 | <p>Fabrication, Supply of outdoor type cubical type LT panel suitable for 415 V, 3 Phase, 4 Wire 50 Hz AC supply system having front surface area as per approved design. The panel should be fabricated in compartmentalized (preferably) design from CRCA sheet steel of 2.0 mm thick for frame work & covers (panel Structure), 1.6 mm thick for door, 3 mm thick for gland plates. Nine tank cleaning process from chemical treatment of the sheet for best finish & quality coating. Powder coating complete with 7 tank process for powder coating in approved shade. The panel having 1000 Amp capacity extensible type TPN aluminium alloy bus bars of high conductivity, DMC/ SMC bus bar supports.</p> <p>Bottom base channel of MS section not less than 100 mm x 50 mm x 5 mm thick ((Hight 900 mm), fabrication shall be done in transportable sections, entire panel shall have a common GI earth bar of size 50 mm x 6 mm at the rear with 2 Nos. earth stud, solid connections from main bus bar to switch gears with required size of Al. bus bars and control wiring (with PVC insulated FRLS copper wire of required size, terminal, lugs, Tape, hardware & accessories), cable alleys, cable gland plates in two half, panel tested up to 6300A at 80 KA @690V, including providing following switch gears:-</p> <p>Incoming</p> <p>01 No. 160 Amps, 36KA 4 Pole Microprocessor type MCCB with Ics=100%Icu with O/L, S/C & E/F protection complete, having on & off trip indication lamp and Spreader Link.</p> <p>LED Multifunction Meter having V, A, F, PF, kW, kVA, kVAR, kWh, kVAh, kVARh, Runhours, On hours, Interrupts, RPM*, % Unbalance (V, A), Phase angle, THD, Neutral current, % Load, Maximum Demand (kW & kVA), MD reset with suitable Accessories- 1 Set with suitable CT's (10VA, 200/5A) and back up MCBs.</p> <p>3 Nos. Phase indicating LED lamps with backup MCBs, breaker ON/OFF/Trip indication light, test terminal block set, MCB, circuits as per standard practice, auxiliary contact for positive interlocking of the breakers, Shunt Trip Coil 220 V AC as required.</p> <p>Bus Bars - TPN aluminium bus bars of minimum 1000 Amp capacity with heat shrinkable coloured sleeves and including DMC/SMC bus bar Cross Section side supports and their spacing etc, for withstanding fault as per CPRI complete with wiring, terminals, lugs, PVC channel with accessories, GI Earth Bus (25x6MM).</p> <p>Outgoing</p> <p>15 Nos. 40 Amps, 10KA 4 Pole C-curve MCB complete with lugs.</p> <p>01 No. 32 Amps Three Phase Industrial Socket inbuild with 32A MCB 4 Pole including Lugs</p> <p>04 Nos. 32 Amps Single Phase Industrial Socket inbuild with 32A MCB 2 Pole including Lugs</p> <p>NOTE:- 1) MCCB's wherever specified shall have extendable rotary handle. 2) All MCCB's shall be provided with phase barriers, phase spreaders link complete as required. 3) The drawing of L.T. Panel to be got approved from Department before fabrication. The panel may be tested in front of representative of the Institute before dispatch. The commissioning may be done by the manufacturer after installation. 4) Manufactured by : Seimens, Mile stone, coremetal craft Ltd., AdLac, Advance, Johns Electric, Neptune. Make of the Swithgears : ABB, Legrand, Schneider, Seimens, L&T</p> | Set | 1 |
|----|---|-----|---|

| | B. Table Tennis Courts | Unit | Qty |
|----|---|-------------|------------|
| 13 | Supply of IK09 rating surface mounting heavy duty Vertical type sheet steel 1.6mm thick Distribution board as per PWD specification for electrical Works ISI marked conforming to IS-13032 & IS-8623/conforming to IEC61439-3 with provision of incomer suitable for MCCB and SP/TP MCB as outgoing, phosphatised, powder painted complete. IP43-Double door with Provision of Incomer MCCB 63/ 100 A Rating - 6 Way. (Make : CG, Bajaj, Wipro, Surya, Havell's, HPL, GE, Pierlite, HalonixPhilips, CG, Bajaj, Wipro, Surya, Havell's) | Each | 1 |
| 14 | Supply of of IP40 quick make and quick break 4 pole current limiting Moulded case circuit breaker (MCCB) made of flame retardent & heat resistant material having following current rating, short circuit breaking capacity at 440/415V, 50Hz; O/L & S/C settings as per PWD specification for electrical Works, conformingtoIS/IEC60947P-2:2003. 63 Amp, 25kA,adjustable O/L & fixed S/C setting, Ics = 100 % Icu (Make: Schneider (neo break), Siemens, HPL, GE , Standard, Indoasian(gold), Havell's, C & S, ABB (S270), L&T, Legrand (Ekinoxe / Lexic)) | Each | 1 |
| 15 | Supply of 240/415V AC MCB with positive isolation of breaking capacity not less than10KA(C tripping characteristic as per type of load and site requirement) 4KV impulse with stand voltage, as per PWD specificationfor electrical Works with ISI marked IS8828(1996)/conforming to IEC60898-12002, IEC60947-2. Single pole MCB -10 A rating. (Make: Schneider (neo break), Siemens, HPL, GE , Standard, Indoasian(gold), Havell's, C & S, ABB (S270),L&T, Legrand (Ekinoxe / Lexic)) | Each | 18 |
| 16 | Supply of P.V.C. / XLPE insulated & P.V.C. sheathed Armoured aluminium cable of 1.1 KV grade as per PWDspecification for electrical Works. - 35.0 Sq. mm, 3.5 core (Make : Gloster ,CCI, Finolex, Rallison, Ekta, Delton, Havell's, KEI, Paramount, Worldcab, Diatron, Unicab,Unistar, Orient cab, Empire, Orbit, Polycab, National) | Mtrs | 35 |
| 17 | Supply of P.V.C. / XLPE insulated & P.V.C. sheathed Armoured aluminium cable of 1.1 KV grade as per PWDspecification for electrical Works. -150.0 Sq. mm, 3.5 core (Make : Gloster ,CCI, Finolex, Rallison, Ekta, Delton, Havell's, KEI, Paramount, Worldcab, Diatron, Unicab,Unistar, Orient cab, Empire, Orbit, Polycab, National) | Mtrs | 120 |
| 18 | Supplying ISI marked P.V.C. insulated submersible cable copper wire as per PWD specification for electrical Works confirming to IS:694 and as per IS 8130 of 1.1 kV grade. Insulation PVC type A,flame retardant as per IS 10810-53. - 1.5 Sq.mm 3 core Round copper cable. (Make RR Kabel , National, Finolex, Rallison, Delton, Eon (Indoasian), KEI, Terexal, Plaza, Anchor,L & T, Standard, Paramount, Empire, Orient Cab, Orbit, HPL, Unicab, Polycab, Havell's, Diatron) | Mtrs. | 270 |
| 19 | Supply of Medium duty rigid PVC conduit - 25MM (The length of the one piece of PVC pipe is approximatle 3 mtrs., one bend, one nipple and three G.I. saddle withCarbon Steel Dry Wall Screw, Size: 6x38 mm may be provided along with one piece of pipe) (Make: AKG, BEC, Precision, Polypack, Shrinath, Polycab, Plaza, Dauphin, Richa) | Mtrs | 180 |

| | | | |
|------|--|------|----|
| 20 | Supply of following modular accessories made out of unbreakable and fire retardant poly carbonate with silver contacts including making connections testing etc. as required. (Make: Schneider electric- Opale, Legrand- Mylinc, Anchor - Roma plus) | | |
| 20.1 | 16 A one way switch | Each | 16 |
| 20.2 | 16 A 6 pin shuttered socket | Each | 16 |
| 21 | Supply of following size mounting grid plates with cover plates as per PWD specification for electrical Works, made from fire retardant UV established high performance engineering plastic suitable for all universal metal boxes for front installation & removal direct fit type complete in all respect. -6 Module. (Make: Schneider electric- Opale, Legrand- Mylinc, Anchor - Roma plus) | Each | 8 |
| 22 | Supply of following size hot dip galvanized M.S. box of 18 SWG as per PWD specification for electrical Works. 6 Module (Make: Schneider electric- Opale, Legrand- Mylinc, Anchor - Roma plus) | Each | 8 |
| 23 | Exhaust Fan (Double ball bearing, capacitor start single phase metallic blade fresh air fan) - 300 mm (Make Almonard, CG, Alstom, Khaitan, Usha, Havells) | Each | 4 |
| 24 | Supply of IK07IP-66 protected high power LED flood light system with Pressure diecast aluminium housing LM6/ADC12 material, toughened glass diffuser with suitable lenses on LED to achieve various beam angles, 240 volt, 50Hz, of high power LED lamps. Integrated driver must be potted & has a unique BISR number shall be high efficiency having efficiency more than 85% and in compliance to BIS certified and T.C. certificate. The System level Luminaire efficacy $\geq 120 \text{lm/wt}$ with High Power LEDs is to be used. LED driver Input Voltage AC120 to 270VAC with High voltage Cut off $\geq 300 \text{VAC}$ and Auto resetting Safety. Input Frequency $50 \text{Hz} \pm 3\%$, Power Factor > 0.95 , driver Efficiency $> 85\%$, THD(I) $< 10\%$, driver current $< 1000 \text{mA}$ shown in LM79 report. driver should be Phase to phase protection of 440V for 4Hrs. Electrical Connector Must be provided, Surge Protection Min $\geq 4 \text{KV}$ internal and 10KV external, System life of 30000 Burning hours with 70% of Initial Lumens maintained, color Rendering Index > 70 and CCT $5700 \text{K} \pm 355 \text{K}$. Manufactures Word Mark/Name Engraved /Embossing/ Screen printing on die cast housing to allow trace ability/authenticity. Fixture shall be IS 10322 Compliant. High Power Hanging type LED Flood Light - 100Watts (Make : CG, Bajaj, Wipro, Surya, Havell's, HPL, GE, Pierlite, Halonix Philips, CG, Bajaj, Wipro, Surya, Havell's) | Each | 8 |
| 25 | Supply of material for Plate Earthing as per PWD specification for electrical Works as per IS:3043 with copper Earth plate of size 600mm x 600mm x 3.0mm. 20 mm dia. G.I. 'B' class watering Pipe (3m), including all accessories like nut, bolts, reducer, nipple, wire meshed funnel, and Heavy duty weather proof polypropylene earth pit chamber with lockable Jam free lid suitable for safe working load 5000 Kg or more of size Top Dia. 225 to 260 mm, Bottom Dia 300 to 350 mm. and Height 250 to 300 mm. salt and coke/ charcoal as per norms. | Set | 1 |

| | | | |
|----|--|-----|---|
| 26 | <p>Fabrication, Supply of outdoor type cubical type LT panel suitable for 415 V, 3 Phase, 4 Wire 50 Hz AC supply system having front surface area as per approved design. The panel should be fabricated in compartmentalized (preferably) design from CRCA sheet steel of 2.0 mm thick for frame work & covers (panel Structure), 1.6 mm thick for door, 3 mm thick for gland plates. Nine tank cleaning process from chemical treatment of the sheet for best finish & quality coating. Powder coating complete with 7 tank process for powder coating in approved shade. The panel having 1000 Amp capacity extensible type TPN aluminium alloy bus bars of high conductivity, DMC/ SMC bus bar supports.</p> <p>Bottom base channel of MS section not less than 100 mm x 50 mm x 5 mm thick ((Hight 900 mm), fabrication shall be done in transportable sections, entire panel shall have a common GI earth bar of size 50 mm x 6 mm at the rear with 2 Nos. earth stud, solid connections from main bus bar to switch gears with required size of Al. bus bars and control wiring (with PVC insulated FRLS copper wire of required size, terminal, lugs, Tape, hardware & accessories), cable alleys, cable gland plates in two half, panel tested up to 6300A at 80 KA @690V, including providing following switch gears:-</p> <p>Incoming</p> <p>01 No. 250 Amps, 36KA 4 Pole Microprocessor type MCCB with Ics=100%Icu with O/L, S/C & E/F protection complete, having on & off trip indication lamp and Spreader Link.</p> <p>LED Multifunction Meter having V, A, F, PF, kW, kVA, kVAR, kWh, kVAh, kVARh, Runhours, On hours, Interrupts, RPM*, % Unbalance (V, A), Phase angle, THD, Neutral current, % Load, Maximum Demand (kW & kVA), MD reset with suitable Accessories- 1 Set with suitable CT's (10VA, 200/5A) and back up MCBs.</p> <p>3 Nos. Phase indicating LED lamps with backup MCBs, breaker ON/OFF/Trip indication light, test terminal block set, MCB , circuits as per standard practice , auxiliary contact for positive interlocking of the breakers, Shunt Trip Coil 220 V AC as required .</p> <p>Bus Bars - TPN aluminium bus bars of minimum 1000 Amp capacity with heat shrinkable coloured sleeves and including DMC/SMC bus bar Cross Section side supports and their spacing etc, for withstanding fault as per CPRI complete with wiring, terminals, lugs, PVC channel with accessories, GI Earth Bus (25x6MM).</p> <p>Outgoing</p> <p>01 Nos. 200 Amps, 25KA 4 Pole Thermal Magnetic Release type MCCB with Ics=100%Icu with O/L, S/C protection complete with spreader link.</p> <p>01 Nos. 160 Amps, 25KA 4 Pole Thermal Magnetic Release type MCCB with Ics=100%Icu with O/L, S/C protection complete with spreader link.</p> <p>06 Nos. 63 Amps, 18KA 4 Pole Thermal Magnetic Release type MCCB with Ics=100%Icu with O/L, S/C protection complete with spreader link.</p> <p>NOTE:- 1) MCCB's wherever specified shall have extendable rotary handle</p> <p>2) All MCCB's shall be provided with phase barriers, phase spreaders link complete as required.</p> <p>3) The drawing of L.T. Panel to be got approved from Department before fabrication. The panel may be tested in front of representative of the Institute before dispatch. The commissioning may be done by the manufacturer after installation.</p> <p>4) Manufactured by : Seimens, Mile stone, coremetal craft Ltd., AdLac, Advance, Johns Electric, Neptune. Make of the Swithgears : ABB, Legrand, Schneider, Seimens, L&T</p> | Set | 1 |
|----|--|-----|---|

Note: Sample of each item shall be approved by engineer-in charge before supply of items

Deputy Registrar
(Store & Purchase)

3. **GENERAL TERMS & CONDITIONS**

3.1. Compliance certificate: This certificate must be provided indicating conformity to the technical specifications. (**Annexure-I**)

3.2. Due date: The tender has to be submitted on or before the due date. The offers received after the due date and time will not be considered.

3.3. Earnest Money Deposit (EMD): The Bidder should submit EMD as per “**Schedule**”. The Bid without EMD would be considered as UNRESPONSIVE and will not be accepted. The EMD will be refunded without any interest to the unsuccessful Bidders after the award of contract. **The bidders are required to submit their bank details/cross cancelled cheque in this regard.** In case of successful bidder, it will be refunded after receipt of Performance Bank Guarantee. **NSIC / MSME registered bidders must submit copy of valid NSIC / MSME Registration Certificate for exemption of EMD.**

3.4. Opening of the tender: The bid will be opened by a committee duly constituted for this purpose. The bids (complete in all respect) received will be opened in presence of bidder’s representative if available. Only one representative will be allowed to participate in the tender opening. Purchase order will be awarded to firm (L₁) quoting lowest price and meeting all technical specifications and conditions.

3.5. Purchase preference to Micro and Small Enterprises (MSEs):

Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference for product/services, the bidder must be the manufacturer/Service provider of the offered product/service. Relevant documentary evidence in this regard shall be submitted along with the bid in respect of the offered service. If L-1 is not an MSE and MSE Service Provider (s) has/have quoted price within L-1+ 15% of margin of purchase preference /price band defined in relevant policy, then 100% order quantity will be awarded to such MSE bidder subject to acceptance of L1 bid price.

3.6. Acceptance/ Rejection of bids: The Institute reserves the right to reject any bid not fulfilling the eligibility criteria. Submission of incomplete bid/ incomplete bid format would lead to rejection of bids. All documents required to be submitted should be the part of the bid. If any document is not submitted, the bid will be treated as incomplete and this would lead to rejection. No communication in this regard will be entertained. Non-compliance of tender terms, non-submission of required documents, lack of clarity of the specifications, contradiction between bidder’s specification and supporting documents etc. may lead to rejection of the bid.

Page 10 of

3.7. Pre Qualification Criteria:

3.7.1. Bidder should be the manufacturer / authorized dealer. Letter of Authorization from Original Equipment Manufacturer (OEM) specific to the tender should be enclosed in the format (**Annexure II**). **Letter of authorization from OEM in any other format or not specific to this tender will not be accepted.**

3.7.2. In the tender, either the Indian agent on behalf of the Principal/OEM or Principal/OEM itself can bid but both cannot bid simultaneously for the same item/product in the same tender.

3.7.3. If an agent submits bid on behalf of the Principal/OEM, the same agent shall not submit a bid on behalf of another Principal/OEM in the same tender for the same item/product.

3.7.4. The Bidder must have successfully executed / completed at least one single order of Rs.

20,55,000.00 or 2 orders each of Rs.12,85,000.00 or 3 orders each of Rs. 10,27,000.00 for similar products in last three years to any IIT/NIT/CFTIs/ any other Govt. organization. Copies of contracts / purchase orders and documentary evidence of successful execution / completion in support of Past Experience of Similar product along with names, address and contact details of clients shall be submitted in the format **(Annexure III)** with the bid for verification by the Buyer.

3.7.5. Only “Class-I and Class-II local supplier will be eligible to bid notified vide (DPIIT) Notification No. P- 45021/2/2017-PP (BE-II) dated 4th June, 2020. It is mandatory for bidders to quote items having local content more than 20%. Refer revised Public Procurement (Preference to Make in India), Order 2017 P-45021/2/2017-B.E-II dated 04.06.2020 issued by DPIIT, Ministry of Commerce and Industry, Govt. of India. **(Submit duly filled Annexure IV for the same)**

3.8. Delivery and Documents:

Delivery of the goods should be made within a maximum period mentioned at the ‘Schedule’ from the date of placement of purchase order.

3.9. Liquidated Damages (L.D):

If a supplier fails to execute the order in time as per the terms and conditions stipulated therein, it will be open to the purchaser to recover liquidated damages for delay in delivery and installation from the supplier at the rate 0.5% of the value of the order per week subject to a maximum of 10% of the total order value. The L.D charges can be increased in case of gross violation of the Purchase Order terms as decided by the Competent Authority of the Institute.

3.10. Place of Jurisdiction: The place of jurisdiction would be Jaipur (Rajasthan).

3.11. Taxes and Duties

Suppliers shall be entirely responsible for all taxes, duties, license fees, octroi, road permits, etc., incurred until delivery of the contracted Goods to the Purchaser. However, GST in respect of the transaction between the Purchaser and the Supplier shall be payable extra, if so stipulated in the order.

3.12. Payment:

- 1) 100% payment shall be made by the Purchaser against delivery, inspection, successful installation, commissioning and acceptance of the equipment at MNIT Jaipur in good condition and to the entire satisfaction of the Purchaser and on production of unconditional performance bank guarantee as specified in bid document.
- 2) GST Deduction at source as per Order/ notification of the Govt.
- 3) GST No of MNIT Jaipur is **08AAAJM0351L1Z6**

3.13. Defective Equipment: If any of the equipment supplied by the Supplier is found to be substandard, refurbished, un-merchantable or not in accordance with the description/specification or otherwise faulty, the committee will have the right to reject the equipment or its part. The prices of such equipment shall be refunded by the Supplier with 18% interest if such payments for such equipment have already been made. All damaged or unapproved goods shall be returned at suppliers cost and risk and the incidental expenses incurred thereon shall be recovered from the supplier. Defective part in equipment, if found before installation and/or during warranty period, shall be replaced within 7 days on receipt of the intimation from this office at the cost and risk of supplier including all other charges. In case supplier fails to replace above item as per above terms & conditions, MNIT Jaipur may consider "Banning" the supplier.

3.14. Genuine Pricing: Vendor is to ensure that quoted price is not more than the price offered to any other customer in India to whom this particular item has been sold.

3.15. Exemption to Startups:

If the bidder is a Startup, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria". In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.

3.16. Exemption to MSME:

If the bidder is a Micro or Small Enterprise as per latest definitions under MSME rules, the bidder shall be exempted from the requirement of "Bidder Turnover" criteria and "Experience Criteria". In case any bidder is seeking exemption from Turnover / Experience Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer.

3.17. Price must be submitted in the prescribed format (Annexure- V**)**

Deputy Registrar
Stores and Purchase MNIT Jaipur

COMPLIANCE SHEET

| Name of Item : Lighting work of table tennis and basket ball courts near Aurobindo Hostel | | | | | |
|--|---|------|-----|-----------------|---------------------|
| S.No. | Particulars | Unit | Qty | Comply (Yes/No) | Supporting Page No. |
| A. Basket ball courts | | | | | |
| 1 | Supply of MS swaged tubular pole conforming to IS:2713-1980 (partItoII) with galvanised base plate, cable entry, GI cable sleeve complete as required. painted with two coat of redoxide primer and two quote of enamel paint of silver colour as per the direction of Engineer in charge. The pole shall be fabricated by using ISI mark tube for structural purpose of following height & designation. (See Table P-02 for specs.) complete in all respect. All as perpre approved by Engineer in charge. For additional technical parameters of products / work, refer Annexure"A" attached with this BSR . (410 SP - 60) Overall Height - 12 Mtr. Base Plate Size - 400 x 400 x 7 mm Length of sections - Bottom - 5.8 mtrs, Middle- 3.1 mtrs, Top - 3.1 mtrs. Outside dia. & thickness of sections - Bottom - 165.1 mm x 5.4 mm, Middle- 139.7mm x 4.5mm, Top - 114.3mmx 3.65mm. | Each | 9 | | |
| 2 | M.S. Sections- 40mm x 40mm X 2.6 mm (thikness)(Make : APOLLO, KALINGA, SWASTIK) | Mtrs | 60 | | |
| 3 | Providing of thermoplastic Polycarbonate cable junction boxes with IP66 rating of protection & knock out for cable entry/out of following sizes including clamps for holding the box, including cost of DIN rail for MCB mounting, 10 Sqmm 4 pole connectors for cables terminals, threaded cable glands made of polyamide material etc. complete in all respect. For additional technical parameters of products/ work , refer Annexure "A" attached with this BSR . 175mm X 150mm X100mm (Make : HPL, Sintex, United) | Nos. | 12 | | |
| 4 | Supply of 240/415V AC MCB with positive isolation of breaking capacity not less than10KA(C tripping characteristic as per type of load and site requirement) 4KV impulse with stand voltage, as per PWD specification for electrical Works with ISI marked IS8828(1996)/conforming to IEC60898-12002, IEC60947-2. Single pole MCB - 10 A rating (Make: Schneider (neo break), Siemens, HPL, GE , Standard, Indoasian(gold), Havell's, C & S, ABB (S270), L&T, Legrand (Ekinoxe / Lexic)) | Each | 28 | | |
| 5 | Supply of P.V.C. / XLPE insulated & P.V.C. sheathed Armoured aluminium cable of 1.1 KV grade as per PWDspecification for electrical Works. - 6.0 Sq. mm, 4 core (Make : Gloster ,CCI, Finolex, Rallison, Ekta, Delton, Havell's, KEI, Paramount, Worldcab, Diatron, Unicab,Unistar, Orient cab, Empire, Orbit, Polycab, National) | Mtrs | 300 | | |

| | | | | | |
|----|--|-------|-----|------------|--|
| 6 | Supply of P.V.C. / XLPE insulated & P.V.C. sheathed Armoured aluminium cable of 1.1 KV grade as per PWD specification for electrical Works. - 70.0 Sq. mm, 3.5 core (Make : Gloster ,CCI, Finolex, Rallison, Ekta, Delton, Havell's, KEI, Paramount, Worldcab, Diatron, Unicab,Unistar, Orient cab, Empire, Orbit, Polycab, National) | Mtrs | 50 | | |
| 7 | Supply of P.V.C. / XLPE insulated & P.V.C. sheathed Armoured aluminium cable of 1.1 KV grade as per PWD specification for electrical Works. - 120.0 Sq. mm, 3.5 core (Make : Gloster ,CCI, Finolex, Rallison, Ekta, Delton, Havell's, KEI, Paramount, Worldcab, Diatron, Unicab,Unistar, Orient cab, Empire, Orbit, Polycab, National) | Mtrs | 120 | | |
| 8 | Supplying ISI marked P.V.C. insulated submersible cable copper wire as per PWD specification for electrical Works confirming to IS:694 and as per IS 8130 : 2013 of 1.1 kV grade. Insulation PVC type A, flame retardant as per IS 10810-53. - 1.5 Sq.mm 3 core Round copper cable (Make RR Kabel , National, Finolex, Rallison, Delton, Eon (Indoasian), KEI, Terexal, Plaza, Anchor,L & T, Standard, Paramount, Empire, Orient Cab, Orbit, HPL, Unicab, Polycab, Havell's, Diatron) | Mtrs. | 400 | | |
| 9 | Supply of IK07IP-66 protected high power LED flood light system with Pressure diecast aluminium housing LM6/ADC12 material, toughened glass diffuser with suitable lenses on LED to achieve various beam angles, 240 volt, 50Hz, of high power LED lamps. Integrated driver must be potted & has a unique BISR number shall be high efficiency having efficiency more than 85% and incompliance to BIS certified and T.C. certificate. The System level Luminaire efficacy ≥ 120 lm/wt with High Power LEDs is to be used. LED driver Input Voltage AC120 to 270VAC with High voltage Cut off ≥ 300 VAC and Auto resetting Safety. Input Frequency $50\text{Hz} \pm 3\%$, Power Factor > 0.95 , driver Efficiency $> 85\%$, THD(I) $< 10\%$, driver current < 1000 mA shown in LM79 report. driver should be Phase to phase protection of 440V for 4Hrs. Electrical Connector Must be provided, Surge Protection Min ≥ 4 KV internal and 10KV external, System life of 30000 Burning hours with 70% of Initial Lumens maintained, color Rendering Index > 70 and CCT $5700\text{K} \pm 355\text{K}$. Manufactures Word Mark/Name Engraved /Embossing/ Screen printing on die cast housing to allow trace ability/authenticity. Fixture shall be IS 10322 Complied. High Power with stand LED Flood Light 400W (Make : CG, Bajaj, Wipro, Surya, Havell's, HPL, GE, Pierlite, Halonix Philips, CG, Bajaj, Wipro, Surya, Havell's) | Each | 28 | Page 14 of | |
| 10 | Supply of material for Plate Earthing as per PWD specification for electrical Works as per IS:3043 with copper Earth plate of size 600mm x 600mm x 3.0mm. 20 mm dia. G.I. 'B' class watering Pipe (3m), including all accessories like nut, bolts, reducer, nipple, wire meshed funnel, and Heavy duty weather proof polypropylene earth pit chamber with lockable Jam free lid suitable for safe working load 5000 Kg or more of size Top Dia. 225 to 260 mm, Bottom Dia 300 to 350 mm. and Height 250 to 300 mm. salt and coke/ charcoal as per norms. | Set | 1 | | |

| | | | | | |
|----|---|------|-------|--|--|
| 11 | <p>Fabrication, Supply of outdoor type cubical type LT panel suitable for 415 V, 3 Phase, 4 Wire 50 Hz AC supply system having front surface area as per approved design. The panel should be fabricated in compartmentalized (preferably) design from CRCA sheet steel of 2.0 mm thick for frame work & covers (panel Structure), 1.6 mm thick for door, 3 mm thick for gland plates. Nine tank cleaning process from chemical treatment of the sheet for best finish & quality coating. Powder coating complete with 7 tank process for powder coating in approved shade. The panel having 1000 Amp capacity extensible type TPN aluminium alloy bus bars of high conductivity, DMC/ SMC bus bar supports.</p> <p>Bottom base channel of MS section not less than 100 mm x 50 mm x 5 mm thick ((Hight 900 mm), fabricationshall be done in transportable sections, entire panel shall have a common GI earth bar of size 50 mm x 6 mm at the rear with 2 Nos. earth stud, solid connections from main bus bar to switch gears with required size of Al. bus bars and control wiring (with PVC insulated FRLS copper wire of required size, terminal, lugs, Tape, hardware & accessories), cable alleys, cable gland plates in two half, panel tested up to 6300A at 80 KA @690V, including providing following switch gears:-</p> <p>Incoming</p> <p>01 No. 200 Amps, 36KA 4 Pole Microprocessor type MCCB with Ics=100%Icu with O/L, S/C & E/F protectioncomplete, having on & off trip indication lamp and Spreader Link.</p> <p>LED Multifunction Meter having V, A, F, PF, kW, kVA, kVAR, kWh, kVAh, kVARh, Runhours, On hours, Interrupts, RPM*, % Unbalance (V, A), Phase angle, THD, Neutral current, % Load, Maximum Demand (kW & kVA), MD reset with suitable Accessories- 1 Set with suitable CT's (10VA, 200/5A) and back up MCBs.</p> <p>3 Nos. Phase indicating LED lamps with backup MCBs, breaker ON/OFF/Trip indication light, test terminalblock set, MCB , circuits as per standard practice , auxiliary contact for positive interlocking of the breakers, Shunt Trip Coil 220 V AC as required .</p> <p>Bus Bars - TPN aluminium bus bars of minimum 1000 Amp capacity with heat shrinkable coloured sleeves and including DMC/SMC bus bar Cross Section side supports and their spacing etc, for withstanding fault as per CPRI complete with wiring, terminals, lugs, PVC channel with accessories, GI Earth Bus (25x6MM).</p> <p>Outgoing</p> <p>3 Nos. 100 Amps, 18KA 4 Pole Thermal Magnetic Release type MCCB with Ics=100%Icu with O/L, S/Cprotection complete with spreader link.</p> <p>3 Nos. 63 Amps, 18KA 4 Pole Thermal Magnetic Release type MCCB with Ics=100%Icu with O/L, S/Cprotection complete with spreader link.</p> <p>NOTE:- 1) MCCB's wherever specified shall have extendable rotary handle.</p> <p>2) All MCCB's shall be provided with phase barriers, phase spreaders link complete as required.</p> <p>3) The drawing of L.T. Panel to be got approved from Department before fabrication. The panel may be tested infront of representative of the Institute before dispech. The commissioning may be done by the manufacturer after installation.</p> <p>4) Manufactured by : Seimens, Mile stone, coremetal craft Ltd., AdLac,Advance, Johns Electric, Neptune. Make ofthe Swithgears : ABB, Legrand, Schneider, Seimens, L&T</p> | Set | 1 | | |
| | | Page | 15 of | | |

| | | | | |
|----|---|-----|---|------------|
| 12 | <p>Fabrication, Supply of outdoor type cubical type LT panel suitable for 415 V, 3 Phase, 4 Wire 50 Hz AC supply system having front surface area as per approved design. The panel should be fabricated in compartmentalized (preferably) design from CRCA sheet steel of 2.0 mm thick for frame work & covers (panel Structure), 1.6 mm thick for door, 3 mm thick for gland plates. Nine tank cleaning process from chemical treatment of the sheet for best finish & quality coating. Powder coating complete with 7 tank process for powder coating in approved shade. The panel having 1000 Amp capacity extensible type TPN aluminium alloy bus bars of high conductivity, DMC/ SMC bus bar supports.</p> <p>Bottom base channel of MS section not less than 100 mm x 50 mm x 5 mm thick ((Hight 900 mm), fabrication shall be done in transportable sections, entire panel shall have a common GI earth bar of size 50 mm x 6 mm at the rear with 2 Nos. earth stud, solid connections from main bus bar to switch gears with required size of Al. bus bars and control wiring (with PVC insulated FRLS copper wire of required size, terminal, lugs, Tape, hardware & accessories), cable alleys, cable gland plates in two half, panel tested up to 6300A at 80 KA @690V, including providing following switch gears:-</p> <p>Incoming</p> <p>01 No. 160 Amps, 36KA 4 Pole Microprocessor type MCCB with Ics=100%Icu with O/L, S/C & E/F protection complete, having on & off trip indication lamp and Spreader Link.</p> <p>LED Multifunction Meter having V, A, F, PF, kW, kVA, kVAR, kWh, kVAh, kVARh, Runhours, On hours, Interrupts, RPM*, % Unbalance (V, A), Phase angle, THD, Neutral current, % Load, Maximum Demand (kW & kVA), MD reset with suitable Accessories- 1 Set with suitable CT's (10VA, 200/5A) and back up MCBs.</p> <p>3 Nos. Phase indicating LED lamps with backup MCBs, breaker ON/OFF/Trip indication light, test terminal block set, MCB , circuits as per standard practice , auxiliary contact for positive interlocking of the breakers, Shunt</p> <p>Trip Coil 220 V AC as required .</p> <p>Bus Bars - TPN aluminium bus bars of minimum 1000 Amp capacity with heat shrinkable coloured sleeves and including DMC/SMC bus bar Cross Section side supports and their spacing etc, for withstanding fault as per CPRI complete with wiring, terminals, lugs, PVC channel with accessories, GI Earth Bus (25x6MM).</p> <p>Outgoing</p> <p>15 Nos. 40 Amps, 10KA 4 Pole C-curve MCB complete with lugs.</p> <p>01 No. 32 Amps Three Phase Industrial Socket inbuild with 32A MCB 4 Pole including Lugs</p> <p>04 Nos. 32 Amps Single Phase Industrial Socket inbuild with 32A MCB 2 Pole including Lugs</p> <p>NOTE:- 1) MCCB's wherever specified shall have extendable rotary handle.</p> <p>2) All MCCB's shall be provided with phase barriers, phase spreaders link complete as required.</p> <p>3) The drawing of L.T. Panel to be got approved from Department before fabrication. The panel may be tested in front of representative of the Institute before dispech. The commissioning may be done by the manufacturer after installation.</p> <p>4) Manufactured by : Seimens, Mile stone, coremetal craft Ltd., AdLac, Advance, Johns Electric, Neptune. Make of the Swithgears : ABB, Legrand, Schneider, Seimens, L&T</p> | Set | 1 | Page 16 of |
|----|---|-----|---|------------|

B. Table Tennis Courts

| | | | | | |
|----|---|-------|-----|--|--|
| 13 | Supply of IK09 rating surface mounting heavy duty Vertical type sheet steel 1.6mm thick Distribution board as per PWD specification for electrical Works ISI marked conforming to IS-13032 & IS-8623/conforming to IEC61439-3 with provision of incomer suitable for MCCB and SP/TP MCB as outgoing, phosphatised, powder painted complete. IP43-Double door with Provision of Incomer MCCB 63/ 100 A Rating - 6 Way. (Make : CG, Bajaj, Wipro, Surya, Havell's, HPL, GE, Pierlite, HalonixPhilips, CG, Bajaj, Wipro, Surya, Havell's) | Each | 1 | | |
| 14 | Supply of of IP40 quick make and quick break 4 pole current limiting Moulded case circuit breaker (MCCB) made of flame retardent & heat resistant material having following current rating, short circuit breaking capacity at 440/415V, 50Hz; O/L & S/C settings as per PWD specification for electrical Works, conformingtoIS/IEC60947P- 2:2003. 63 Amp, 25kA,adjustable O/L & fixed S/C setting, Ics = 100 % Icu (Make: Schneider (neo break), Siemens, HPL, GE , Standard, Indoasian(gold), Havell's, C & S, ABB (S270), L&T, Legrand (Ekinoxe / Lexic)) | Each | 1 | | |
| 15 | Supply of 240/415V AC MCB with positive isolation of breaking capacity not less than10KA(C tripping characteristic as per type of load and site requirement) 4KV impulse with stand voltage, as per PWD specificationfor electrical Works with ISI marked IS8828(1996)/conforming to IEC60898-12002, IEC60947-2. Single pole MCB -10 A rating. (Make: Schneider (neo break), Siemens, HPL, GE , Standard, Indoasian(gold), Havell's, C & S, ABB (S270),L&T, Legrand (Ekinoxe / Lexic)) | Each | 18 | | |
| 16 | Supply of P.V.C. / XLPE insulated & P.V.C. sheathed Armoured aluminium cable of 1.1 KV grade as per PWDspecification for electrical Works. - 35.0 Sq. mm, 3.5 core (Make : Gloster ,CCI, Finolex, Rallison, Ekta, Delton, Havell's, KEI, Paramount, Worldcab, Diatron, Unicab,Unistar, Orient cab, Empire, Orbit, Polycab, National) | Mtrs | 35 | | |
| 17 | Supply of P.V.C. / XLPE insulated & P.V.C. sheathed Armoured aluminium cable of 1.1 KV grade as per PWDspecification for electrical Works. -150.0 Sq. mm, 3.5 core (Make : Gloster ,CCI, Finolex, Rallison, Ekta, Delton, Havell's, KEI, Paramount, Worldcab, Diatron, Unicab,Unistar, Orient cab, Empire, Orbit, Polycab, National) | Mtrs | 120 | | |
| 18 | Supplying ISI marked P.V.C. insulated submersible cable copper wire as per PWD specification for electrical Works confirming to IS:694 and as per IS 8130 : 2013 of 1.1 kV grade. Insulation PVC type A, flame retardant as per IS 10810-53. - 1.5 Sq.mm 3 core Round copper cable. (Make RR Kabel , National, Finolex, Rallison, Delton, Eon (Indoasian), KEI, Terexal, Plaza, Anchor,L & T, Standard, Paramount, Empire, Orient Cab, Orbit, HPL, Unicab, Polycab, Havell's, Diatron) | Mtrs. | 270 | | |
| 19 | Supply of Medium duty rigid PVC conduit - 25MM (The length of the one piece of PVC pipe is approximatle 3 mtrs., one bend, one nipple and three G.I. saddle withCarbon Steel Dry Wall Screw, Size: 6x38 mm may be provided along with one piece of pipe) (Make: AKG, BEC, Precision, Polypack, Shrinath, Polycab, Plaza, Dauphin, Richa) | Mtrs | 180 | | |

| | | | | | |
|------|--|-------------|------------|--|--|
| 20 | Supply of following modular accessories made out of unbreakable and fire retardant poly carbonate with silvercontacts including making connections testing etc. as required. (Make: Schneider electric- Opale, Legrand- Mylinc, Anchor - Roma plus) | | | | |
| 20.1 | 16 A one way switch | Each | 16 | | |
| 20.2 | 16 A 6 pin shuttered socket | Each | 16 | | |
| 21 | Supply of following size mounting grid plates with cover plates as per PWD specification for electrical Works, made from fire retardent UV established high performance engineering plastic suitable for all universal metal boxesfor front installation & removal direct fit type complete in all respect. -6 Module. (Make: Schneider electric- Opale, Legrand- Mylinc, Anchor - Roma plus) | Each | 8 | | |
| 22 | Supply of following size hot dip galvanized M.S.box of 18 SWG as per PWD specification for electrical Works.6 Module (Make: Schneider electric- Opale, Legrand- Mylinc, Anchor - Roma plus) | Each | 8 | | |
| 23 | Exhaust Fan (Double ball bearing, capacitor start single phase metallic blade fresh air fan) - 300 mm (Make Almonard, CG, Alstom, Khaitan, Usha, Havells) | Each | 4 | | |
| 24 | Supply of IK07IP-66 protected high power LED flood light system with Pressure diecast aluminium housing LM6/ADC12 material, toughened glass diffuser with suitable lenses on LED to achieve various beam angles, 240 volt, 50Hz, of high power LED lamps. Integrated driver must be potted & has a unique BISR number shall be high efficiency having efficiency more than 85% and incompliance to BIS certified and T.C. certificate. The System level Luminaire efficacy \geq 120lm/wt with High Power LEDs is to be used. LED driver Input Voltage AC120 to 270VAC with High voltage Cut off \geq 300VAC and Auto resetting Safety. Input Frequency 50Hz \pm 3%, Power Factor $>$ 0.95, driver Efficiency $>$ 85%, THD(I) $<$ 10%, drivercurrent $<$ 1000mA shown in LM79 report. driver should be Phase to phase protection of 440V for 4Hrs. Electrical Connector Must be provided, Surge Protection Min \geq 4KV internal and10KV external, System life of 30000 Burning hours with 70% of Initial Lumens maintained, color Rendering Index $>$ 70 and CCT5700K \pm 355K. Manufactures Word Mark/Name Engraved /Embossing/ Screen printing on die cast housing to allow trace ability/authenticity. Fixture shall be IS 10322 Complianced. High Power Hanging type LED Flood Light - 100Watts (Make : CG, Bajaj, Wipro, Surya, Havell's, HPL, GE, Pierlite, HalonixPhilips, CG, Bajaj, Wipro, Surya, Havell's) | Each | 8 | | |
| 25 | Supply of material for Plate Earthing as per PWD specification for electrical Works as per IS:3043 with copper Earth plate of size 600mm x 600mm x 3.0mm. 20 mm dia. G.I. 'B' class watering Pipe (3m), including all accessories like nut, bolts, reducer, nipple, wire meshed funnel, and Heavy duty weather proof polypropylene earth pit chamber with lockable Jam free lid suitable for safe working load 5000 Kg or more of size Top Dia. 225 to 260 mm, Bottom Dia 300 to 350 mm. and Height 250 to 300 mm. salt and coke/ charcoal as per norms. | Page Set | 18 of 1 | | |

| | | | | | |
|------------|--|-----|---|--|--|
| 26 | <p>Fabrication, Supply of outdoor type cubical type LT panel suitable for 415 V, 3 Phase, 4 Wire 50 Hz AC supply system having front surface area as per approved design. The panel should be fabricated in compartmentalized (preferably) design from CRCA sheet steel of 2.0 mm thick for frame work & covers (panel Structure), 1.6 mm thick for door, 3 mm thick for gland plates. Nine tank cleaning process from chemical treatment of the sheet for best finish & quality coating. Powder coating complete with 7 tank process for powder coating in approved shade. The panel having 1000 Amp capacity extensible type TPN aluminium alloy bus bars of high conductivity, DMC/ SMC bus bar supports.</p> <p>Bottom base channel of MS section not less than 100 mm x 50 mm x 5 mm thick ((Hight 900 mm), fabricationshall be done in transportable sections, entire panel shall have a common GI earth bar of size 50 mm x 6 mm at the rear with 2 Nos. earth stud, solid connections from main bus bar to switch gears with required size of Al. bus bars and control wiring (with PVC insulated FRLS copper wire of required size, terminal, lugs, Tape, hardware & accessories), cable alleys, cable gland plates in two half, panel tested up to 6300A at 80 KA @690V, including providing following switch gears:-</p> <p>Incoming</p> <p>01 No. 250 Amps, 36KA 4 Pole Microprocessor type MCCB with Ics=100%Icu with O/L, S/C & E/F protection complete, having on & off trip indication lamp and Spreader Link.</p> <p>LED Multifunction Meter having V, A, F, PF, kW, kVA, kVAR, kWh, kVAh, kVARh, Runhours, On hours, Interrupts, RPM*, % Unbalance (V, A), Phase angle, THD, Neutral current, % Load, Maximum Demand (kW & kVA), MD reset with suitable Accessories- 1 Set with suitable CT's (10VA, 200/5A) and back up MCBs.</p> <p>3 Nos. Phase indicating LED lamps with backup MCBs, breaker ON/OFF/Trip indication light, test terminal block set, MCB , circuits as per standard practice , auxiliary contact for positive interlocking of the breakers, ShuntTrip Coil 220 V AC as required .</p> <p>Bus Bars - TPN aluminium bus bars of minimum 1000 Amp capacity with heat shrinkable coloured sleeves and including DMC/SMC bus bar Cross Section side supports and their spacing etc, for withstanding fault as per CPRI complete with wiring, terminals, lugs, PVC channel with accessories, GI Earth Bus (25x6MM).</p> <p>Outgoing</p> <p>01 Nos. 200 Amps, 25KA 4 Pole Thermal Magnetic Release type MCCB with Ics=100%Icu with O/L, S/C protection complete with spreader link.</p> <p>01 Nos. 160 Amps, 25KA 4 Pole Thermal Magnetic Release type MCCB with Ics=100%Icu with O/L, S/C protection complete with spreader link.</p> <p>06 Nos. 63 Amps, 18KA 4 Pole Thermal Magnetic Release type MCCB with Ics=100%Icu with O/L, S/C protection complete with spreader link.</p> <p>NOTE:- 1) MCCB's wherever specified shall have extendable rotary handle.</p> <p>2) All MCCB's shall be provided with phase barriers, phase spreaders link complete as required.</p> <p>3) The drawing of L.T. Panel to be got approved from Department before fabrication. The panel may be tested infront of representative of the Institute before dispech. The commissioning may be done by the manufacturer after installation.</p> | Set | 1 | | |
| Page 19 of | | | | | |

| | | | | | |
|----|---|--|--|--|--|
| | 4) Manufactured by : Seimens, Mile stone, coremetal craft Ltd., AdLac, Advance, Johns Electric, Neptune. Make of the Swithgears : ABB, Legrand, Schneider, Seimens, L&T | | | | |
| 27 | Proof of Earnest Money Deposit | | | | |
| 28 | Copy of GST Certificate and PAN | | | | |
| 29 | Non Blacklisting of Supplier and Price reasonability declaration | | | | |
| 30 | Required past Experience | | | | |
| 31 | Minimum average annual turnover of the bidder | | | | |
| 32 | After Sale Service Certificate | | | | |
| 33 | Manufacturer's Authorization Letter | | | | |
| 34 | Declaration of Local Content | | | | |

Note: Sample of each item shall be approved by engineer-in charge before supply of items

Signature of Bidder

Name: _____

Designation: _____

Organization Name: _____

Contact No.: _____

MANUFACTURERS' AUTHORIZATION FORM

[The bidder shall require the Manufacturer to fill in this Form in accordance with the Instructions indicated. This letter of authorization should be on the letter head of the Manufacturer and should be signed by a person with the proper authority to sign documents that are binding on the Manufacturer]

Date: [insert date (as day, month and year) of Bid Submission] Tender No.: [insert number from Invitation forBids]

To: [insert complete name and address of Purchaser] WHEREAS

We [insert complete name of Manufacturer], who are official manufacturers of [insert type of goods manufactured], having factories at [insert full address of Manufacturer's factories], do hereby authorize [insert complete name of Bidder] to submit a bid the purpose of which is to provide the following Goods, manufactured by us [insert name and or brief description of the Goods], and to subsequently negotiate and sign the Contract.

We hereby extend our full guarantee and warranty in accordance with Clause 4.23 of the Terms and Conditions, with respect to the Goods offered by the above firm. Further We also ensure to support on regular basis with technology / product updates.

Signed: [insert signature(s) of authorized representative(s) of the Manufacturer]

Name: [insert complete name(s) of authorized representative(s) of the Manufacturer]

Title: [insert title]

Duly authorized to sign this Authorization on behalf of: [insert complete name of Bidder]

Dated on day of , [insert date of signing]

Past Experience details

| List of Organizations for whom the bidder has undertaken such work during last three years (must be supported with Purchase orders) | | | |
|--|------------------------|-------------|------------------------------------|
| Name of the organization | Name of Contact Person | Contact No. | Copy of Purchase Orders (Page no.) |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |

Note: Without submission of relevant Purchase orders, experience will not be considered.

Signature of Bidder

Name: _____

Designation: _____

Organization Name: _____

Contact No.: _____

DECLARATION OF LOCAL CONTENT

[For Local Content of Products, Services or Works]

(To be given on Company Letter Head – For tender value below Rs.10 Crores)

(To be given by Statutory Auditor/Cost Auditor/Cost Accountant/CA for tender value above Rs.10 Crores)

To,
The Registrar
MNIT Jaipur

Subject: Declaration of Local Content

Tender reference No. _____

1. Country of Origin of Goods being offered: _____
2. With reference to Order No. P- 45021/2/2017-PP(BE-II) dated 16-09-2020 of DPIIT, Ministry of Commerce and Industry, Govt. of India, we fall under the following category of supplier (please tick the correct category) for the items for which this tender has been floated and being bided.
 - Class I local supplier – has local content equal to more than 50%. Local contents added at _____ (name of location).
 - Class II local supplier – has local content more than 20% but less than 50%. Local content sadded at _____ (name of location).
 - Non-local supplier – has local content less than or equal to 20%. Local contents added at _____ (name of location).
3. We are solely responsible for the above mentioned declaration in respect of category of supplier. False declarations will be in breach of the Code of Integrity under Rule 175(1)(i)(h) of the General Financial Rules for which we may be debarred for up to 2 years as per Rule 151(iii) of the General Financial Rules along with such other actions as may be permissible under law.

Signature of Bidder/ Agent

Name: _____

Designation: _____

Organization Name: _____

Contact No. : _____

PRICE BID FORMAT

| 1 | 2 | 3 | 4 | 5 | | | 6 |
|---------|---|------|------|---------------------|-------------------------|----------------------|----------------------------------|
| | | | | Price (Rs.) | | | |
| Sl. No. | Name Item with Description | Unit | Qty. | 5 (A) Unit Price | 5 (B) Price 4 x 5(a) | 5 (C) GST payable | Total Item price 6= 5(b)+5(c) |
| 1 | Item No. 1 (as per compliance sheet) | Each | 9 | | | | |
| 2 | Item No. 2 (as per compliance sheet) | Mtrs | 60 | | | | |
| 3 | Item No. 3 (as per compliance sheet) | Nos. | 12 | | | | |
| 4 | Item No. 4 (as per compliance sheet) | Each | 28 | | | | |
| 5 | Item No. 5 (as per compliance sheet) | Mtrs | 300 | | | | |
| 6 | Item No. 6 (as per compliance sheet) | Mtrs | 50 | | | | |
| 7 | Item No. 7 (as per compliance sheet) | Mtrs | 120 | | | | |
| 8 | Item No. 8 (as per compliance sheet) | Mtrs | 400 | | | | |
| 9 | Item No. 9 (as per compliance sheet) | Each | 28 | | | | |
| 10 | Item No. 10 (as per compliance sheet) | Set | 1 | | | | |
| 11 | Item No. 11 (as per compliance sheet) | Set | 1 | | | | |
| 12 | Item No. 12 (as per compliance sheet) | Set | 1 | | | | |
| 13 | Item No. 13 (as per compliance sheet) | Each | 1 | | | | |
| 14 | Item No. 14 (as per compliance sheet) | Each | 1 | | | | |
| 15 | Item No. 15 (as per compliance sheet) | Each | 18 | | | | |
| 16 | Item No. 16 (as per compliance sheet) | Mtrs | 35 | | | | |
| 17 | Item No. 17 (as per compliance sheet) | Mtrs | 120 | | | | |
| 18 | Item No. 18 (as per compliance sheet) | Mtrs | 270 | | | | |
| 19 | Item No. 19 (as per compliance sheet) | Mtrs | 180 | | | | |
| 20 | Item No. 20 (as per compliance sheet) | | | | | | |
| | Item No. 20.1 (as per compliance sheet) | Each | 16 | | | | |
| | Item No. 20.2 (as per compliance sheet) | Each | 16 | | | | |
| 21 | Item No. 21 (as per compliance sheet) | Each | 8 | | | | |
| 22 | Item No. 22 (as per compliance sheet) | Each | 8 | | | | |

| | | | | | | | |
|-----------|---------------------------------------|------|---|--|--|--|--|
| 23 | Item No. 23 (as per compliance sheet) | Each | 4 | | | | |
| 24 | Item No. 24 (as per compliance sheet) | Each | 8 | | | | |
| 25 | Item No. 25 (as per compliance sheet) | Set | 1 | | | | |
| 26 | Item No. 26 (as per compliance sheet) | Set | 1 | | | | |
| | | | | | | | |
| | Total | | | | | | |
| | If any other cost (Please specify) | | | | | | |
| | GRAND TOTAL | | | | | | |

Total bid price (for Indian components) in Indian Currency*: (in figures) :

(in words):

Signature of Bidder/ Agent

Name: _____

Designation _____

