



Malaviya National Institute of Technology Jaipur
J.L.N. Marg, Jaipur – 302 017

Date 22.08.2022

Corrigendum

NIT No- : MNIT/NIT/E/2022-23/02
Name of the work : Providing and Laying of Aluminium armoured cable for Library.

The last date of the bid submission of tender is hereby extended up to
01.09.2022 at 6:00 PM.

In G-schedule the Size of cable mention in a column 4 at Sr. No. 1.2 may be
read as 120.0 Sq. mm instead of 95.0 Sq. mm.

The bidder those already submitted their bid are required to resubmit their Bid
otherwise their bid will be rejected.

Narayan Dasg.
Executive Engineer